



# CERTIFICATE OF COMPLIANCE

**Certificate Number:** SGSNA/22/GZ/00171

**Contract Number:** 800341

**Certificate Project Number:** GZ-CERT220701646

**Certified Product:** Hybrid Inverter

**Trademarks:** Sol-Ark

**Model(s):** Sol-Ark-12k-P, Sol-Ark-9K-48-ST, Sol-Ark-8K-48-ST Sol-Ark-5K-48-ST

**Technical Data:** See Page 2

**Certificate Holder:** Portable Solar LLC (dba Sol-Ark)  
1100 Professional Dr, Plano, Texas 75074, United States of America

*This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at [www.sgs.com](http://www.sgs.com) or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:*

UL 1741, Third Edition, Dated September 28, 2021 (including UL 1741 Supplement SB)

CSA C22.2 NO. 107.1-16

Compliance with IEEE Std 1547:2018 (Revision of IEEE Std 1547:2003), approved 15 February 2018;

IEEE Std 1547a™-2020 Approved 9 March 2020. (Refer to IEEE Std 1547.1:2020, approved 5 March 2020, using IEEE 2030.5 protocol)

Hawaiian Electric Companies, IEEE 1547.1-2020 Source Requirements Document Version 2.0 ("SRD V2.0"), effective on July 1st, 2020

Photovoltaic (PV) DC Arc-Fault Circuit Protection-UL 1699B: First Edition, Dated August 22, 2018

Authorized by:

Effective date: 08 August 2022



Jason Wei  
Certifier



## Certification Body

Connectivity & Products, a division of SGS North America Inc.  
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA  
t +1 770 570 1800 f +1 770 277 1240 [www.sgs.com](http://www.sgs.com)





# CERTIFICATE OF COMPLIANCE

**Certificate Number:** SGSNA/22/GZ/00171

**Contract Number:** 801651

**Certificate Project Number:** GZ-CERT220701646

**Technical Data:** Sol-Ark-12k-P

AC side:

AC Voltage@120/240V: 240V(211V-264V), 37.5A, 9000W(L-L) / 4500W(L-N), 60Hz,

AC Voltage@120/208V: 208V(183V-229V), 37.5A, 7800W(L-L) / 4500W(L-N), 60Hz

PV side: 150dc-500Vdc (MPPT range:175Vdc-425Vdc), 20A/20A

Battery side: 48Vdc(43Vdc-63Vdc), 185A

Sol-Ark-9K-48-ST

AC side:

AC Voltage@120/240V: 240V(211V-264V), 37.5A, 9000W(L-L) / 4500W(L-N), 60Hz,

AC Voltage@120/208V: 208V(183V-229V), 37.5A, 7800W(L-L) / 4800W(L-N), 60Hz

PV side: 150dc-500Vdc (MPPT range:175Vdc-425Vdc), 18A/18A

Battery side: 48Vdc(43Vdc-63Vdc), 185A

Sol-Ark-8K-48-ST

AC side:

AC Voltage@120/240V: 240V(211V-264V), 33.0A, 8000W(L-L) / 4000W(L-N), 60Hz,

AC Voltage@120/208V: 208V(183V-229V), 33.3A, 6900W(L-L) / 4000W(L-N), 60Hz

PV side: 150dc-500Vdc (MPPT range:175Vdc-425Vdc), 18A/18A

Battery side: 48Vdc(43Vdc-63Vdc), 185A

Sol-Ark-5K-48-ST

AC side:

AC Voltage@120/240V: 240V(211V-264V), 20.8A, 5000W(L-L) / 2500W(L-N), 60Hz,

AC Voltage@120/208V: 208V(183V-229V), 29.1A, 5000W(L-L) / 2500W(L-N), 60Hz

PV side: 150dc-500Vdc (MPPT range:175Vdc-425Vdc), 10A/10A

Battery side: 48Vdc(43Vdc-63Vdc), 120A

## Certification Body

Connectivity & Products, a division of SGS North America Inc.  
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA  
t +1 770 570 1800 f +1 770 277 1240 [www.sgs.com](http://www.sgs.com)